

**SJPNL**  
**WATER TESTING LABORATORY**  
**WATER SUPPLY GUMMA, SHIMLA 171018**

*Based upon CPHEEO MANUAL*

[Division.....WSD SHIMLA]

**Sample** [CRAIGNANO]

**Date:** - 21-05-2022

TIME OF SAMPLING:-11:00 AM

[Sub Division ...WSSD GUMMA

TIME OF COMENCING:-02:40 PM

**WATER SAMPLE**

1. Raw Water
2. Filtered Water
- >> 3. Chlorinated Water
4. Distributed System

**A. PHYSICAL TESTS**

Tests	1 Acceptable	2 Cause of Rejection	3 Result of Sample
1. Temp			20°C
2. Turbidity [NTU]	2.5	10	1 NTU
3. Conductivity	.....	.....	416 µS/cm
4. Total Dissolved solids	500	1500	208 mg/l

**B. CHEMICAL TEST**

1. PH	7 to 8.5	Less than 6.2 more than 9.2	7.98
2. Total hardness	200	600	178 mg/l
3. Chlorides	200	1000	24.992 mg/l
4. Total Alkalinity	200	400	142 mg/l
5. Residual Chlorine	02-0.5[mg/l desirable]		<b>5.0 mg/l</b>

**C. BACTERIOLOGICAL TESTS**

*No of coli form Organisms*

*After 48 hours MPN in*

*100 ml water sample*

*NIL*

*NIL*

*.....NIL.....MPN*

*Coli form count should be zero in any sample of 100 ml from water entering the distributed system*

**Remarks**.....

Asst. Chemist  
 Water Test Lab.  
 Gumma.

Junior Engineer  
 Water Supply SJPNL  
 Gumma, Shimla.

Manager-2  
 Water Supply SJPNL  
 Gumma, Shimla.