

# SHIMLA JAL PRABHDHAN NIGAM LTD.

## TEST REPORT

- **BACTERIOLOGICAL TESTS (MPN/100)**
- **Date of collection of sample:-01-10-2023**
- **Date of commencing:- 01-10-2023**
- **Date of Reporting:- 03-10-2023 (after 48 hours of incubation)**

**After 24-48 hours of incubation, the MPN in 100 ml of water sample:-**

Sample	Volumes of sample		MPN for 100 ml
	50 ml	10 ml	
Filtered water	0	0	0
Raw water	1	5	18

**Note:- Bacteriological tests are under incubation of 48 hours.**

- **Coli form count should be zero in any sample of 100 ml of water entering the distribution system.**

**Chemist**

**Water testing laboratory**

**Ashwanikhad**

