

SJPNL
WATER TESTING LABORATORY
BULK WATER SUPPLY GUMMA SHIMLA 171018

Based upon CPHEEO MANUAL
 [Division.....WSD SHIMLA]

Date: -25-07-2025

Sample [CRAIGNANO]

TIME OF SAMPLING: - 09:15 AM

[Sub Division ...WSSD GUMMA

TIME OF COMENCING: - 03:05 PM

WATER SAMPLE

1. Raw Water
2. Filtered Water
- >> 3. Chlorinated Water
4. Distributed System

A. PHYSICAL TESTS

Tests	1 Acceptable	2 Cause of Rejection	3 Result of Sample
1. Temp			21°C
2. Turbidity [NTU]	1	5	2.6 NTU
3. Conductivity	318 µS/cm
4. Total Dissolved solids	500	2000	206.7 mg/l

B. CHEMICAL TEST

1. PH	7 to 8.5	Less than 6.5 more than 8.5	7.98
2. Total hardness	200	600	144 mg/l
3. Chlorides	250	1000	23.992 mg/l
4. Total Alkalinity	200	400	106 mg/l
5. Residual Chlorine	02-0.5[mg/l desirable]		3.0 mg/l

C. BACTERIOLOGICAL TESTS

No of coli form Organisms

After 48 hours MPN in

100 ml water sample


NIL

NIL

.....NIL.....MPN

Coli form count should be zero in any sample of 100 ml from water entering the distributed system

Remarks.....


 Asst. Chemist
 Water Test Lab.
 Gumma.

Junior Engineer
 Bulk Water Supply SJPNL
 Gumma, Shimla.

Manager-2
 Bulk Water Supply SJPNL
 Gumma, Shimla.