

SHIMLA JAL PRABHDHAN NIGAM LTD.

TEST REPORT

Report No.	LSWW for Shimla city
Name and address of sender	Koti Bharandi (Been Nala)
Division	Water distribution division
Sub-division	Sanjauli
Name of scheme and location of source	W.T.P. Ashwanikhad
Date and time of collection	26-02-2026 at 11:00 AM
Date and time of receipt at laboratory	26-02-2026 at 11:15 AM
Date and time of commencing	26-02-2026 at 11:30 AM
Type of sample	Filter water
Quantity of sample	500 ml
Date of reporting	26-02-2026
Testing protocol	IS10500:2012

A. PHYSICAL TESTS

S.no.	Tests	Acceptable limit	Permissible limit in the absence of alternate source	Result of sample
1.	Temperature (° C)			4.3 ° C
2.	Turbidity [NTU]	1	5	0.97 NTU
3.	Conductivity (µS)			89.4 µs
4.	Total Dissolved Solids (Mg/L or ppm)	500	2000	62.6 ppm
5.	Color (Hazen)	5	15	48 Pt/Co(Hz) (Range:25-1000 Pt/Co(Hz))
6.	Odour	Agreeable	Agreeable	No odour
7.	Taste	Agreeable	Agreeable	Normal

B. CHEMICAL TESTS

S.No.	Tests	Acceptable limit	Permissible limit in the absence of alternate source	Result of sample
1.	pH value	6.5-8.5	No relaxation	7.89
2.	Total Alkalinity (Mg/l)	200	600	30 mg/l
3.	Chlorides (Mg/l)	250	1000	11.364 mg/l
4.	Total Hardness (Mg/l)	200	600	68 mg/l
5.	Residual Chlorine (Mg/l or ppm)	0.2	1.0	1.0 ppm
6.	Nitrate (Mg/l)	45	No relaxation	5 mg/l (Range; 0.3-30.0 mg/l)
7.	Iron (Mg/l)	0.1	1.0	0.01 mg/l (Range; 0.01-2.00 mg/l)
8.	Fluoride (Mg/l)	1.0	1.5	0.66 mg/l (Range; 0.08-2.00 mg/l)
9.	Sulphate (Mg/l)	200	400	11.3 mg/l (Range; 1.0-25.0 mg/l)
10.	Manganese (Mg/l)	0.1	0.3	0.02 mg/l (Range; 0.05-6.00 mg/l)

Chemist

Water testing laboratory

Ashwanikhad

