

# SHIMLA JAL PRABHDHAN NIGAM LTD.

## TEST REPORT

<b>Report No.</b>	LSWW for Shimla city
<b>Name and address of sender</b>	Koti Bharandi (Been Nala)
<b>Division</b>	Water distribution division
<b>Sub-division</b>	Sanjauli
<b>Name of scheme and location of source</b>	W.T.P. Ashwanikhad
<b>Date and time of collection</b>	08-04-2026 at 11:00 AM
<b>Date and time of receipt at laboratory</b>	08-04-2026 at 11:15 AM
<b>Date and time of commencing</b>	08-04-2026 at 11:30 AM
<b>Type of sample</b>	Raw water
<b>Quantity of sample</b>	500 ml
<b>Date of reporting</b>	08-04-2026
<b>Testing protocol</b>	<b>IS10500:2012</b>

### A. PHYSICAL TESTS

S.no.	Tests	Acceptable limit	Permissible limit in the absence of alternate source	Result of sample
1.	Temperature (° C)			8.8° C
2.	Turbidity [NTU]	1	5	2.04 NTU
3.	Conductivity (µS)			128.6 µs
4.	Total Dissolved Solids (Mg/L or ppm)	500	2000	89.2 ppm
5.	Color (Hazen)	5	15	<b>Underrange</b> (Range:25-1000 Pt/Co(Hz))
6.	Odour	Agreeable	Agreeable	<b>No odour</b>
7.	Taste	Agreeable	Agreeable	<b>Normal</b>

## B. CHEMICAL TESTS

S.No.	Tests	Acceptable limit	Permissible limit in the absence of alternate source	Result of sample
1.	pH value	6.5-8.5	No relaxation	<b>8.19</b>
2.	Total Alkalinity (Mg/l)	200	600	<b>35 mg/l</b>
3.	Chlorides (Mg/l)	250	1000	<b>11.395 mg/l</b>
4.	Total Hardness (Mg/l)	200	600	<b>66 mg/l</b>
5.	Residual Chlorine (Mg/l or ppm)	0.2	1.0	<b>1.5 ppm</b>
6.	Nitrate (Mg/l)	45	No relaxation	<b>BDL</b> (Range; 0.3-30.0 mg/l)
7.	Iron (Mg/l)	0.1	1.0	<b>0.04 mg/l</b> (Range; 0.01-2.00 mg/l)
8.	Fluoride (Mg/l)	1.0	1.5	<b>0.72 mg/l</b> (Range; 0.08-2.00 mg/l)
9.	Sulphate (Mg/l)	200	400	<b>14.1 mg/l</b> (Range; 1.0-25.0 mg/l)
10.	Manganese (Mg/l)	0.1	0.3	<b>0.03 mg/l</b> (Range; 0.05-6.00 mg/l)

## C. BACTERIOLOGICAL TESTS (MPN/100)

**Note:- Bacteriological tests are under incubation of 48 hours.**

**C. BACTERIOLOGICAL TESTS (MPN/100)**

- **Date of collection of sample:-06-04-2026**
- **Date of commencing:- 06-04-2026**
- **Date of Reporting:- 08-04-2026 (after 48 hours of incubation)**

**After 24-48 hours of incubation, the MPN in 100 ml of water sample:-**

Sample	Volumes of sample		MPN for 100 ml
	50 ml	10 ml	
Raw water	1	5	18

- **Coli form count should be zero in any sample of 100 ml of water entering the distribution system.**

**Chemist**

**Water testing laboratory**

**Ashwanikhad**

