

RESULTS OF BACTERIOLOGICAL SAMPLES RECEIVED ON DATED 10-01-2021

Sr. No.	Collection Date	Lab. Code	Location of Sample Taken	ANALYSIS RESULTS		Final Reporting Date
				Total Coliform MPN/100 ml	E.Coli MPN/100 ml	
1	10.01.2021	2121	Kasumpati reservoir	<1.1	Not Required	13-01-2021
2		2122	Phase-III tank no-1	<1.1	Not Required	13-01-2021
3		2123	Jakhu tank near hanuman temple	<1.1	Not Required	13-01-2021
4		2124	P. Tap Near Summerhill Chowk	<1.1	Not Required	13-01-2021
5		2125	P. tap near raj diaary summerhill	<1.1	Not Required	13-01-2021
6		2126	Summerhill bazar tank	<1.1	Not Required	13-01-2021
7		2127	P. Tap Near Lower Summerhill	<1.1	Not Required	13-01-2021
8		2128	P. tap near 18 family boiluganj	<1.1	Not Required	13-01-2021
9		2129	Kamna Devi Tank	<1.1	Not Required	13-01-2021
10		2130	P. tap near hari mandir chakker	<1.1	Not Required	13-01-2021
11		2131	Chakker tank	<1.1	Not Required	13-01-2021
12		2132	Bhimakali tank	<1.1	Not Required	13-01-2021
13		2133	TutiKandi Tank	<1.1	Not Required	13-01-2021
14		2134	Bharari Tank	<1.1	Not Required	13-01-2021
15		2135	Sanjauli reservoir	<1.1	Not Required	13-01-2021
16		2136	Giri inlet	<1.1	Not Required	13-01-2021
17		2137	Gumma Inlet	<1.1	Not Required	13-01-2021
18		2138	Kalyani tank Charabra	<1.1	Not Required	13-01-2021
19		2139	Mainsfield tank	<1.1	Not Required	13-01-2021
20		2140	Knollswood Tank	<1.1	Not Required	13-01-2021