

RESULTS OF BACTERIOLOGICAL SAMPLES RECEIVED ON DATED 29-12-2020

Sr. No.	Collection Date	Lab. Code	Location of Sample Taken	ANALYSIS RESULTS		Final Reporting Date
				Total Coliform MPN/100 ml	E.Coli MPN/100 ml	
1	29.12.2020	1881	Kasumpti Reservoir	<1.1	Not Required	01-01-2021
2		1882	P. tap near Chadha transport	<1.1	Not Required	01-01-2021
3		1883	P. tap near Gaddi khana	<1.1	Not Required	01-01-2021
4		1884	P. tap near Suji line	16	<1.1	01-01-2021
5		1885	P. tap near eva sales corporation ganj bazar	23	<1.1	01-01-2021
6		1886	P. tap near prushartha basti	<1.1	Not Required	01-01-2021
7		1887	P. tap near sabji mandi lower bazar	<1.1	Not Required	01-01-2021
8		1888	P. Tap near Indira Chowk, Lower Bazar	1.1	<1.1	01-01-2021
9		1889	P. tap near khadi bhandar the mall shimla	<1.1	Not Required	01-01-2021
10		1890	P. tap near samsung shop the mall shimla	<1.1	Not Required	01-01-2021
11		1891	P. tap near HPMC ridge shimla	<1.1	Not Required	01-01-2021
12		1892	Kleston Tank	<1.1	Not Required	01-01-2021
13		1893	Sanjauli Reservoir	<1.1	Not Required	01-01-2021
14		1894	Giri Inlet	<1.1	Not Required	01-01-2021
15		1895	Gumma Inlet	<1.1	Not Required	01-01-2021
16		1896	Dhalli Tank Outlet	<1.1	Not Required	01-01-2021
17		1897	Jakhu Tank near Hanuman Temple	<1.1	Not Required	01-01-2021
18		1898	Mainsfield Tank	<1.1	Not Required	01-01-2021
19		1899	Knollswood Tank	<1.1	Not Required	01-01-2021
20		1900	Phase-III, Tank No.-1	<1.1	Not Required	01-01-2021