

RESULTS OF BACTERIOLOGICAL SAMPLES RECEIVED ON DATED-22.04.2021

Sr. No.	Collection Date	Lab. Code	Location of Samples Taken	ANALYSIS RESULTS		Final Reporting Date
				Total Coliform MPN/100 ml	E.Coli MPN/100 ml	
1	22.04.2021	4161	Kasumpati Reservoir	<1.1	Not Required	4/25/2021
2		4162	Dhalli Tank Outlet	2.2	<1.1	4/25/2021
3		4163	P.Tap Near Goel Apartment Dhingu	16	<1.1	4/25/2021
4		4164	Dhingu Mandir Tank	12	<1.1	4/25/2021
5		4165	Engine Ghar Tank	23	<1.1	4/25/2021
6		4166	P.Tap Near Mehta Parking	<1.1	Not Required	4/25/2021
7		4167	P.Tap Near Bangala Colony	<1.1	Not Required	4/25/2021
8		4168	Bangala Colony Tank	<1.1	Not Required	4/25/2021
9		4169	Klestan Tank	9.2	<1.1	4/25/2021
10		4170	Bharari Tank	16	<1.1	4/25/2021
11		4171	P.Tap Near Bhagwati Niwas Lakkar Bazar	>23	<1.1	4/25/2021
12		4172	Bhimakali Tank	16	<1.1	4/25/2021
13		4173	Advancestudy Tank	12	<1.1	4/25/2021
14		4174	Sanjouli Reservoir	>23	>23	4/25/2021
15		4175	Giri Inlet	12	12	4/25/2021
16		4176	Gumma Inlet	9.2	<1.1	4/25/2021
17		4177	Mainsfield Tank	16	16	4/25/2021
18		4178	Knollswood Tank	23	<1.1	4/25/2021
19		4179	Tara Mata Mandir Tank	>23	<1.1	4/25/2021
20		4180	Phase III Tank no-3	>23	<1.1	4/25/2021